Intertek

Certificate

for European Product Safety

Intertek

Reference No. 1018177

Heating cable, self-regulating

Type designation	ICEGUARD-18
Certificate holder	**Danfoss A/S** **Danfoss Heating Solutions** **Ulvehavevej 61** **DK-7100 Vejle** **DENMARK**
The product complies with the standard(s)	SS 424 24 11:1992
Date of expiry	19 August 2015
EU Directive information	*The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed Pär Iggström *Date* 19 August 2010

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

Intertek

Intertek

Appendix

Reference No. 1018177

Technical data

Type designation	Iceguard 18
Rated Voltage (V)	230
Number of Conductors	2 + screen
Rated power (W)	18 W/m
Product information	Designation according SS: 65BM. With ending 12/3 or 19/5.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.
Replaces previously issued Appendix dated 19 August 2010.
A new Appendix has been issued on account of missprintings.

Manufacturing site(s)

Danfoss Sp. Z o.o.
ul. Chrzanowska 5
05-825 Grodzisk Maz
POLAND

Danfoss A/S
Danfoss Heating Solutions
Ulvehavevej 61
DK-7100 Vejle
DENMARK

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed Magnus Wahlgren *Date* 27 August 2010

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

 LBIB

Intertek

Replaced 27/8-2010

Intertek

Appendix

Reference No. 1018177

Technical data

Type designation	ICEGUARD-18
Rated Voltage (V)	230
Number of Conductors	2 + screen
Rated power (W)	18 W/m
Product information	Designation according SS: 65BM. With ending.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

Manufacturing site(s)

BACAB S.A.
Rue de l'industrie 19
CH-1450 Sainte-Croix
SWITZERLAND

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed Pär Iggström *Date* 19 August 2010

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LBE

Intertek

26 Aug. 2010

Danfoss A/S
Danfoss Heating Solutions
Ulvehavevej 61
DK-7100 Vejle
DANMARK

Handled by
Magnus Wahlgren
Direct telephone
+46 8 750 02 34
Reference
1018177
E-mail
magnus.wahlgren@intertek.com
Your Reference
Verner Utoft

19 August 2010

Intertek S Mark Certificate with No. 1018177
We are pleased to enclose the Intertek S Mark Certificate you have applied for.

Thank You for S Marking your Products!
You have taken the first step to S Mark, but have you taken the next step by letting your customers know about your investment? When you use the S Mark in your marketing you are making clear that your company is truly committed to quality and safety. Positioning and differentiate yourself as a company which is dedicated to safety enables you to increase your sales – because in Europe safety sells.

The S Mark is highly recognized among retailers and authorities since 1926.

The S Mark also strengthens your brand by signaling that safety is important to your company and that you care about the safety of your clients. Since we value you as a customer we want to make sure you are getting the best value out of the S Mark. Many of our customers are already using the S Mark in their marketing. Popular media to use the mark is in campaigns, on packaging and in product catalogues. To find out more and to download tools, please visit www.sweden.intertek-etlsemko.com/smark.

If you have any questions don't hesitate to contact us at info-sweden@intertek.com

Additional part of the certification
In addition to your product certification, we are conducting inspections at your manufacturing site/s. The inspections are carried out by our inspectors or subcontractors. For details of the technical requirements for these inspections, please contact inspection.etlsemko@intertek.com.

Your success is important to us!

Best Regards,

Göran Lilja
Executive Vice President
Intertek Semko AB

Pär Zetterberg
Executive Vice President
Intertek Semko AB

S 114 10-06 Strömberg 164234